

Certificate



Aktiengesellschaft

No. z2341c-10-E

Customer:

Assmann Electronic GmbH
Auf dem Schüffel 3
D-58513 Lüdenscheid

Test sample(s):

- Connector:
Digitus Cat 6 Class EA, Tool Free Keystone Module, shielded
Part No.: DN-93614
- Data Cable:
Digitus Cat 7 S-FTP 4x2xAWG23 LSOH Installation cable
Part No.: DK-1741-VH-10
- Patchcord:
Digitus Cat 6 Class EA 4x2xAWG26 LSOH Patchcord
Part No.: DK-1641-A-020, DK-1643-A-020

Applied standard(s):

- ISO/IEC 11801 AMD 1 (2008-04)

Results:

Up to a bandwidth of **500 MHz** the sample meet the **Class E_A** limits of the specified standards and regulations.

Channel, Class E_A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2341c-10-E**, from **April 20th, 2012** and shall only be applicable in conjunction with the test report.

Bexbach, April 20th, 2012

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 - 0
Fax: +49 (0) 68 26 / 92 28 - 99
Email: info@ghmt.de