



Compliance Statement

Screened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Four Connector Channel


Aginode Belgium n.v./s.a.
Alsembergsesteenweg 2, b3,
1501 Buizingen, Belgium

Compliance Statement No. 0473-3P-1241077

This type of Class EA / Category 6A Screened Four Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018 incl. appendix 1 and 2. The Compliance Statement is valid for the actually tested channel samples, consisting of the listed components. The tested channel is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 19 February 2027.

Cables:	<i>Horizontal Cable (5 - 80 m), Qualification Status:</i>	<i>P/N N100.62xG-yz Manufacturer verified</i>
Conn. Hardware:	<i>Modular Jack, Qualification Status:</i>	<i>P/N N420.960 Manufacturer verified</i>
Consolidation Cords:	<i>(5 m), Qualification Status:</i>	<i>P/N N11A.U1F050yz Manufacturer verified</i>
Patch and equipment Cords:	<i>(2 m, 5 m), Qualification Status:</i>	<i>P/N N11A.U1F020yz / P/N N11A.U1F050yz Manufacturer verified</i>

Hoersholm, 19 August 2024


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 19 August 2024


Jens Rytter Petersen
General Manager